

14/64

E

254

WU/C/1/4

FUEL RESEARCH INSTITUTE OF SOUTH AFRICA

TECHNICAL MEMORANDUM NO. 14 OF 1964



REPORT ON DUST COLLECTOR TESTS AT  
UMGENI POWER STATION, BOILER NO. 9,  
NOVEMBER 26TH, 1963

BY

I.C. ERASMUS

and

H.B. VAN HEERDEN

FUEL RESEARCH INSTITUTE OF SOUTH AFRICA

TECHNICAL MEMORANDUM NO. 14 OF 1964

REPORT ON DUST COLLECTOR TESTS AT  
UMGENI POWER STATION, BOILER NO. 9,  
NOVEMBER 26TH, 1963

INTRODUCTION:

The tests reported herein were carried out on behalf of Messrs. Davidson & Co. (Africa) Ltd., the suppliers of the Dust Collector Plant, for the purpose of determining the efficiency of the installation.

A preliminary test was carried out on the dust collectors of No. 9 boiler on the 26th and 27th November, 1963. An E.C.R. and an M.C.R. test were performed. The tests were carried out during boiler trials.

PART I. DESCRIPTION OF APPARATUS AND TEST METHOD.

The operation of the dust collector was judged by weighing the total quantity of fine ashes collected by the equipment over a set period and by assessing the dust emitted from the boiler by sampling the flue gases at the dust collector outlet.

1.1 Fine Ash Collected

Determination of the quantity of fine ashes collected consisted of weighing all the dust caught by the primary and secondary collectors. To this effect temporary pipes were run from the two primary and the two secondary collector outlets (after the dust valves) to within a few feet of the floor.

The dust emitted from each of these valves was collected in dust bins, closed with a tightly fitting lid, connected by a flexible canvas sleeve to the valve outlet.

The filled bins were weighed and a sample of approximately half a pound taken from each bin.

The ashes collected at the right- and left-hand sides of the boiler were weighed at regular intervals, the results being given in Tables Nos. 1 and 2 for E.C.R. and Tables Nos. 3 and 4 for M.C.R.

1.2 Flue Dust Sampling Equipment

Flue dust sampling was carried out isokinetically and in accordance with B.S. 893 : 1940. For this purpose the sampling head illustrated in Figure 1 was used. The equipment comprises a Pitot tube, by means of which the flue gas velocity is determined, and a sampling probe through which the gas is exhausted at a velocity closely corresponding to that deduced from the Pitot tube indication. The gas then passes a miniature cyclone, in which most of the dust is precipitated, then a glass-wool filter, and finally a small shaped nozzle installed for the purpose of measuring the quantity of flue gas aspirated. For details of the construction, see Figure 2.

In/...




Figure I.

In addition, the sampling head contains a thermocouple by means of which the flue gas temperature may be determined.

The complete assembly is supported by a thin-walled steel tube of 2 inches diameter, through which the exhaust pipe and measuring tubes and the thermocouple wires are passed.

The equipment was designed to pass through 8" diameter sampling ports in the duct. During the test the port is closed by a heavy steel cover to which a tubular guide for the thin-walled tube is welded. A clamping device ensures that the sampling head may be rigidly fixed in any desired position.

The exhaust line, measuring tubes and thermocouple leads are extended to the measuring equipment, mounted in a case. This apparatus contains:

- (a) A sliding-vane type exhauster with control valves;
- (b) An inclined gauge (0 to 20 mm. by 0.2 mm. water column), connected to the Pitot tube, indicating the flue gas velocity head;
- (c) A U-tube connected to pressure taps on both sides of the orifice plate; this gauge thus indicates the pressure drop across the orifice.
- (d) A U-tube, connected to the Pitot static line and the atmosphere, indicating the draught or suction in the flue;
- (e) An aneroid barometer and a clock;
- (f) A spot-light galvanometer, connected by copper leads to two terminals embedded in an aluminium block upon which the thermocouple leads terminate.

The temperature of the block was measured by means of a mercury thermometer.


## 2. SAMPLING PROCEDURE:

In principle the test procedure is as follows: The sampling head is inserted in the duct in a suitable position, which in this test was situated before the I.D.



UMGENI POWER STATION

BOILER No.9



SECTION OF DUCT

FIG.3

the particular probe, in this case  $\frac{1}{8}$ " , based on information collected during preliminary tests. This generally adequately covers the requirements of B.S. 893 : 1940, which allows the exhaust velocity to deviate by plus or minus 10% of the gas velocity.

Observations taken during the tests are presented in Tables Nos. 5, 6, 7 and 8.

### 3. CALIBRATION OF EQUIPMENT

The thermocouples are continuous from the hot junction to the terminals in the cold junction, which largely eliminated parasitic thermal electro-motive forces.

The thermocouples were calibrated (together with their galvanometers) by inserting them in small cavities in a copper block, previously heated to 200°C and left to cool. The temperature of the copper block was measured by means of a mercury thermometer, that of the cold junction by the thermometers installed on the apparatus. Readings, as set out in Table No. C 1, were taken at appropriate intervals.

During sampling, the flue gas temperature is thus found as the sum of cold junction temperature and galvanometer deflection, converted to degrees of temperature.

#### 3.1 Nozzle Calibration

##### (a) Introductory Remarks:

The purpose of this calibration is to establish the relationship between the volume rate of flow through the cyclone and the pressure drop occurring in the nozzle. By calculation this relation can then be converted into that between pressure drop and linear velocity in the probe.

Though conditions during calibration differ from those during actual use (as the calibration is carried out using air at room temperature and pressure), these differences have usually no significant effect.

##### (b) Method of Calibration:

The experimental set-up during calibration is indicated in Figure 4. It will be noted that calibration

was/...

was effected on the complete sampling head, i.e. the orifice was preceded by the probe and the filter; the pressure drop during calibration does thus not differ materially from that experienced during the test.

The volume rate of flow was measured by means of a Fisher and Porter Rotameter (No. B4-21-10 with stainless steel float No. BSVT-45). According to the manufacturer's calibration data, the flow rate is proportional to the instrument reading in the range from 8% to 100% of the maximum flow, where 100% corresponds to a flow rate of 2.48 ft<sup>3</sup>/minute of air at 70°C and 14.7 lbs/in<sup>2</sup> abs. These statements were verified and found to be substantially correct. (c.f. Table C 3). The manufacturers further state that viscosity effects are negligible and that adjustments for other conditions are to be made on the basis of the density.\*

During calibration, nozzle pressure drop, rotameter reading, pressure at rotameter intake, air pressure and temperature were recorded. (The humidity during these tests was so low that the air density was not appreciably affected.)

(c) Evaluation of Orifice Calibration Test Data

These test data are tabulated in Table No. C 3, and are evaluated as follows:

The rotameter flow rates listed in Table C 2 are those for the atmospheric conditions operative during the experiment. As, however, a slight pressure drop,  $p_r$ ,

occurs/...

---

\* In principle, the rotameter is a slightly tapered vertical tube through which the fluid is passed from bottom to top. In doing so, the medium has to force its way past the float, which then assumes such a position that the pressure difference across the annular space between float and tube wall balances the float weight  $W$ , hence

$$W = \frac{K \gamma}{2g} v_a^2$$

where  $\gamma$  is the density of the fluid,  $K$  a constant and  $v_a$  the velocity in the annulus. Hence it follows that if the density  $\gamma_1$  at a particular test differs from that at the standard condition,

$\gamma_0$  (70°C, 14.7 psia, air), the actual volume flow rate  $Q_1$  for a particular deflection, say 100%, has to be derived from the "standard" quantity at 100% according to the equation

$$Q_1 = Q_0 \sqrt{\gamma_0 / \gamma_1}$$



occurs at the rotameter point of entry, the air in the rotameter is a little lighter than at the probe entry. Consequently, the flow rate  $Q_1$ , as indicated by the rotameter, is a little higher than that at the probe entry,  $Q$ , the latter following from the former according to the equation:

$$Q = Q_1 \sqrt{\frac{B - p_r}{B}}$$

where  $B$  equals the absolute air pressure,  $p_r$  the pressure drop at the rotameter, expressed in the same units. As

$$p_r \ll B, \quad Q = Q_1 \left(1 - \frac{p_r}{2B}\right).$$

Table No. C 4 then shows the corrected flow rate, expressed in terms of the linear velocity  $v_2$  in the probe in relation to the pressure drop across the nozzle. As both  $\frac{1}{8}$ " and  $\frac{3}{8}$ " nominal bore probes may be used, data for both probes are incorporated.

(d) Use of Test Data

In practice, during the actual sampling procedure the velocity  $v_2$  in the probe has to be made equal - as nearly as possible - to the gas velocity  $v_1$  at the sampling point. However,  $v_1$  is not determined directly, but by means of the dynamic pressure  $p_v = \frac{\gamma}{2g} v_1^2$  generated in the Pitot tube, and thus related to  $v_1$  by a square law.

Likewise, the probe velocity  $v_2$  follows indirectly from the nozzle pressure drop  $p_0$ , which is related to  $v_2$ , if not exactly by a square law, by an equation closely resembling such a law.

It thus appears expedient to relate the two quantities  $p_0$  and  $p_v$ , which are observed directly, to each other, as  $p_0$  and  $p_v$  may be expected to stand to each other in a nearly, though not necessarily absolutely, constant ratio.

One would thus express  $p_0$  in terms of the velocity head in the probe, i.e. one would put

$$p_0 = \beta \frac{\gamma}{2g} v_2^2 = \beta p_v'$$

As already mentioned, the operator is provided with a table giving him the value of  $p_0$  to be maintained in relation to the velocity head  $p_v$ .

above data referring to the coal as fired, but on an ash-free basis.

Assuming 30% excess air, the composition of the wet flue gas would be:

CO <sub>2</sub>	-	13%	(on dry basis 14%)
O <sub>2</sub>	-	4.6%	
N <sub>2</sub> +Ar	-	74.9%	
H <sub>2</sub> O	-	7.5%	

(with air of 30% relative humidity at 27°C).

At 0°C and 760 mm. Hg. the (fictitious) density of such a flue gas would be 1.328 kg/m<sup>3</sup>. (0.0829 lbs/ft<sup>3</sup>).

## 5. TEST RESULTS:

The actual tests were performed on the lines set out in the previous paragraphs. The test results are represented in Tables 1 to 14, these being derived from the data sheets completed during the tests.

## 6. GAS VOLUMES AND ASH QUANTITIES:

### 6.1 Calculation of Gas Velocity in Duct

This velocity follows directly from the Pitot tube readings taken at the various sampling points. Denoting the velocity head by  $p_v$ , the velocity  $v_1$  in the duct follows from the equation:

$$v_1 = \sqrt{\frac{2g}{\gamma} p_v}$$

where  $\gamma$  equals the specific gravity of the flue gas under test conditions and  $g$  the acceleration due to gravity. As  $p_v$  was determined in mm. H<sub>2</sub>O, the velocity follows in m/sec. when  $g$  and  $\gamma$  are expressed in the appropriate metric units (m/sec<sup>2</sup> and kg/m<sup>3</sup>); conversion to feet per second requires multiplication by the factor 3.2808.

As the actual flue gas composition is not known at the present stage, a flue gas as indicated in paragraph 4, has been assumed to exist, with a fictitious density of 1.328 kg/m<sup>3</sup> (0.0829 lbs/ft<sup>3</sup>) at 0°C and a pressure of 760 mm. Hg.

The/...

The data of Tables 5 to 8 have been treated as follows:-

(a) For each sampling point, the mean value of  $\sqrt{p_v}$ , resulting from the three readings taken at this point, has been obtained, using the indications of the inclined gauge.

(b) The density under actual conditions,  $\gamma_1$  is then calculated from the assumed figure  $\gamma_0 = 1.328 \text{ kg/m}^3$  at  $0^\circ\text{C}$ , 760 mm. Hg. by means of the conversion

$$\gamma_1 = \gamma_0 \frac{B}{760} \frac{273}{T}$$

## 6.2 Calculation of the Aspiration Velocity

For each sampling point the average value of the three pressure-drop readings across the nozzle has been determined, the readings as tabulated in Tables 5 to 8 being used for this purpose.

Using the diagrams of Figure C 1, the value  $p_v'$ , the velocity head in the probe may be read off for each value of  $p_0$ . The correction for the viscosity effect could be introduced at this point; it is, however, more convenient to do so in the final stage, i.e. when calculating the total quantity of gas aspirated.

From  $\sqrt{p_v'}$  the velocity  $v'$  may be calculated in the same manner as in section (1), the results being shown in Tables 11, 12, 13 and 14.

## 6.3 Calculation of Flue Gas Volume and Gas Quantity Aspirated

(a) The velocity at each of the 24 sampling points is considered to be representative for the area in the centre of which this point is situated. As it is desired to calculate only the gas volume emitted by the boiler during the actual sampling period (24 x 10 minutes), the gas volume  $Q$  follows from the equation

$$Q = 240 \sum \frac{A_i}{144} \times 60 v_i = 100 \sum A_i v_i$$

where  $v_i$  equals the flue gas velocity (expressed in feet per second) in the sampling point  $i$ , and  $A_i$  the

area/...

area of the surface (expressed in square inches) in which point  $i$  is situated, c.f. Table 15. The calculations are summarized in Tables 16 and 17.

(b) The quantity of gas aspirated,  $Q_2$ , follows from the consideration that sampling occurred through the area of the probe for a period of 600 seconds in each of the sampling points.

Consequently, in the point  $i$  the volume  $Q_i = 600 A_p \cdot v_i$  is aspirated, where  $A_p$  denotes the probe area in  $\text{ft}^2$ , (c.f. Table C.4), and  $v_i$  the aspiration or probe velocity in feet per second. The total volume, exhausted during the test, thus equals  $Q_2 = 600 A_p \Sigma v_i$ , where  $\Sigma v_i$  is obtained from Tables 11, 12, 13 and 14.

The results of the calculation are shown in Tables 18 and 19.

These tables also indicate the ratio  $Q : Q_2 = R$  (gas volume emitted to gas volume sampled) as well as the theoretical value  $R'$ , following from the ratio of duct area to probe area, and the correction factor  $K$ , by means of which the quantity of dust, collected in the sampling equipment, has to be multiplied.

#### 6.4 Gross Collector Efficiency and Dust Burden

The collector efficiency follows from the equation:

$$\eta = \frac{W_1}{W_1 + W_2} \quad 100\%$$

where  $W_1$  equals the quantity of dust collected,  $W_2$  the quantity of dust emitted, where both  $W_1$  and  $W_2$  have to be determined for identical periods. The latter may be calculated from  $W = wQ/Q_2 K = wRK$ , where  $w$  equals the weight of the dust collected in the sampling apparatus which has been indicated in Tables 16 and 17. This thus covers dust sampled in an active sampling period of 4 hours, but because of the time involved in changing the position of the probe every 10 minutes, the total sampling time  $t$  is longer than 4 hours.

TABLE NO. C 1

THERMOCOUPLE CALIBRATIONDATE: 1-3-1963

TEMPERATURE, °C			MILLIVOLTS		$\mu$ V/°C	
HOT JUNCTION	COLD JUNCTION	DIFF.	COUPLE NO. 1	COUPLE NO. 2	COUPLE NO. 1	COUPLE NO. 2
244	26	218	11.8	11.2	54.13	51.38
235	26	209	11.7	11.3	55.98	54.07
230	26	204	11.5	11.1	56.37	54.41
225	26	199	11.25	10.8	56.53	54.27
220	26	194	10.95	10.55	56.44	54.38
215	26	189	10.65	10.25	56.35	54.23
210	26	184	10.35	10.00	56.25	54.35
205	26	179	10.05	9.7	56.15	54.19
200	26	174	9.8	9.4	56.32	54.02
190	26	164	9.15	8.80	55.79	53.65
180	26	154	8.6	8.25	55.84	53.57
170	26	144	8.0	7.70	55.56	53.47
160	26	134	7.4	7.10	55.22	52.98
150	26	124	6.8	6.55	54.84	52.82
140	26	114	6.2	6.00	54.39	52.63
130	26	104	5.65	5.45	54.33	52.40
120	26	94	5.10	4.90	54.26	52.13
110	26	84	4.50	4.35	53.57	51.79
100	26	74	3.95	3.80	53.38	51.35
90	26	64	3.40	3.35	53.13	52.34
80	26	54	2.85	2.70	52.78	50.00
70	26	44	2.25	2.17	51.14	49.32
60	26	34	1.70	1.65	50.00	48.53

AVERAGE: 54.73 52.71



TABLE NO. C 2

ORIFICE CALIBRATION

(Observed Data)

Test →		a	a	b	b
	Rotameter Reading	Pressure Drop at Rotameter Inlet	Pressure Drop across Orifice	Pressure Drop at Rotameter Inlet	Pressure Drop across Orifice
	%	mm. H <sub>2</sub> O			
Orifice No. 1, 1/4" dia.	20	7	2.87	9	2.44
	30	18	5.91	20	5.60
	40	33	10.07	34	10.26
	50	52	15.21	52	15.32
	60	70	21.27	74	21.71
	70	93	28.11	96	28.57
	80	120	36.07	124	36.39
	90	149	44.72	152	45.37
	100	182	54.47	180	54.86
		Date:	7/10/57		8/10/57
	Temp.	21.5°C		24.3°C	
	Baro.	25.7" Hg.		25.7" Hg.	
Orifice No. 2, 1/4" dia.	20	10	2.65	10	2.21
	30	22	5.56	21	5.58
	40	38	9.84	36	9.94
	50	56	15.42	55	15.45
	60	83	21.48	76	21.48
	70	110	28.89	100	28.72
	80	126	36.37	126	35.98
	90	150	45.79	154	45.34
	100	188	55.82	193	56.00
		Date:	7/10/57		8/10/57
	Temp.	24.8°C		24.3°C	
	Baro.	25.6" Hg.		25.7" Hg.	



TABLE NO. C 4  
ORIFICE CALIBRATION

ORIFICE NO. 1,  $\frac{1}{4}$ "

Rotameter Reading	Correction	$\frac{1}{8}$ " Probe		Pressure drop across Orifice P <sub>0</sub>	$\frac{3}{8}$ " Probe		Remarks
		Velocity in Probe	Velocity Head P <sub>V</sub>		Velocity	Head P <sub>V</sub>	
%	%	m/sec	mm. H <sub>2</sub> O	mm. H <sub>2</sub> O	mm. H <sub>2</sub> O		
a 20	0	1.95	0.199	2.87	0.650	Ratio of Velocity Head $\frac{3}{8}$ " Probe to $\frac{1}{8}$ " Probe. $(\frac{1.284}{0.955})^4 = 3.268$ $\gamma = 1.029$ $P_V = \frac{v^2}{19.05} = 0.0524 v^2$	
30	0.1	2.93	0.450	5.91	1.471		
40	0.2	3.89	0.794	10.07	2.595		
50	0.3	4.87	1.245	15.21	4.069		
60	0.4	5.83	1.784	21.27	5.830		
70	0.5	6.80	2.427	28.11	7.931		
80	0.7	7.75	3.153	36.07	10.30		
90	0.8	8.71	3.982	44.72	13.01		
100	0.9	9.66	4.899	54.47	16.01		
b 20	0	1.96	0.200	2.44	0.654		$\gamma = 1.019$
30	0.1	2.94	0.449	5.60	1.467	$P_V = \frac{v^2}{19.23} = 0.0520 v^2$	
40	0.2	3.91	0.795	10.26	2.598		
50	0.3	4.90	1.249	15.32	4.082		
60	0.4	5.87	1.792	21.71	5.856		
70	0.6	6.84	2.433	28.57	7.951		
80	0.7	7.80	3.164	36.39	10.34		
90	0.9	8.75	3.981	45.37	13.01		
100	1.1	9.71	4.903	54.86	16.02		

ORIFICE NO. 2,  $\frac{1}{4}$ "

a 20	0	2.01	0.209	2.65	0.670	Ratio of Velocity Head $\frac{3}{8}$ " Probe to $\frac{1}{8}$ " Probe. $(\frac{1.274}{0.953})^4 = 3.205$ $P_V = \frac{v^2}{19.33} = 0.0517 v^2$ $\gamma = 1.014$
30	0.1	3.01	0.468	5.56	1.500	
40	0.2	4.00	0.827	9.84	2.651	
50	0.3	5.00	1.293	15.42	4.144	
60	0.4	6.00	1.861	21.48	5.965	
70	0.6	6.98	2.519	28.39	8.073	
80	0.7	7.96	3.276	36.37	10.50	
90	0.9	8.95	4.141	45.79	13.27	
100	1.1	9.92	5.088	55.82	16.31	
b 20	0	2.00	0.208	2.21	0.666	
30	0.1	3.00	0.468	5.58	1.500	
40	0.2	3.99	0.828	9.94	2.654	
50	0.3	4.98	1.290	15.45	4.134	
60	0.4	5.98	1.860	21.48	5.961	
70	0.6	6.96	2.519	28.72	8.073	
80	0.7	7.94	3.278	35.98	10.51	
90	0.9	8.92	4.138	45.34	13.26	
100	1.1	9.89	5.086	56.00	16.30	

TABLE NO. 1

DUST COLLECTED

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9							
DATE: 26-11-1963							
LOAD: E.C.R.							
RIGHT HAND SIDE							
TIME hr.min.	WEIGHT, lbs.			TIME hr.min.	WEIGHT, lbs.		
	INCREMENT	CUMULATIVE			INCREMENT	CUMULATIVE	
9.15	28.5	6.0	34.5	13.15	22.0	7.5	489.5
9.30	18.5	5.0	58.0	13.30	22.0	7.5	519.0
9.45	17.0	6.0	81.0	13.45	25.0	8.5	552.5
10.00	18.5	5.5	105.0	14.00	22.5	8.5	583.5
10.15	19.5	5.5	130.0	14.15	23.0	7.5	614.0
10.30	19.5	7.0	156.5	14.30	22.5	8.5	645.0
10.45	28.5	7.5	192.5	14.45	22.5	7.5	675.0
11.00	19.5	7.0	219.0	15.00	21.5	8.5	705.0
11.15	20.0	7.0	246.0	15.15	17.5	7.5	730.0
11.30	25.0	9.5	280.5	15.30	29.0	9.5	768.5
11.45	22.0	8.0	310.5	15.45	41.5	38.5	848.5
12.00	22.5	8.0	341.0	16.00	29.5	8.5	886.5
12.15	22.0	7.5	370.5	16.15	18.0	6.5	911.0
12.30	22.5	7.5	400.5	16.30	22.5	8.0	941.5
12.45	22.0	7.5	430.0	16.45	17.5	6.5	965.5
13.00	22.0	8.0	460.0	17.00	17.5	6.5	989.5

TABLE NO. 2

DUST COLLECTED

DUST COLLECTOR TEST AT UMGENI POWER STATION, BOILER NO. 9

DATE: 26-11-1963

LOAD: E.C.R.

LEFT HAND SIDE

TIME hr.min.	WEIGHT, lbs.		TIME hr.min.	WEIGHT, lbs.			
	INCREMENT	CUMULATIVE		INCREMENT	CUMULATIVE		
9.15	13.0	19.5	32.5	13.15	13.0	19.5	539.0
9.30	11.5	16.0	60.0	13.30	13.5	19.5	572.0
9.45	11.0	17.5	88.5	13.45	14.5	21.5	608.0
10.00	10.5	16.5	115.5	14.00	13.5	19.5	641.0
10.15	10.5	18.5	144.5	14.15	12.5	19.5	673.0
10.30	11.0	19.0	174.5	14.30	13.5	20.5	707.0
10.45	12.5	19.0	206.0	14.45	14.5	19.5	741.0
11.00	14.0	18.0	238.0	15.00	12.5	20.5	774.0
11.15	12.0	19.0	269.0	15.15	12.5	17.5	804.0
11.30	15.5	26.0	310.5	15.30	16.5	27.5	848.0
11.45	11.5	16.5	338.5	15.45	35.5	45.5	929.0
12.00	12.5	20.5	371.5	16.00	13.5	12.5	955.0
12.15	13.0	18.5	403.0	16.15	11.5	16.0	982.5
12.30	14.0	20.0	437.0	16.30	12.5	21.5	1016.5
12.45	12.0	20.0	469.0	16.45	10.5	14.5	1041.5
13.00	13.0	24.5	506.5	17.00	10.5	15.5	1067.5



TABLE NO. 3  
DUST COLLECTED

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9

DATE: 27-11-1963

LOAD: M.C.R.

RIGHT HAND SIDE

TIME hr.min.	WEIGHT, lbs.		TIME hr.min.	WEIGHT, lbs.			
	INCREMENT	CUMULATIVE		INCREMENT	CUMULATIVE		
9.15	38.5	14.0	52.5	13.15	40.5	16.5	1078.0
9.30	45.5	17.5	115.5	13.30	45.5	24.5	1148.0
9.45	45.5	17.5	178.5	13.45	37.5	17.5	1203.0
10.00	45.5	18.0	242.0	14.00	38.5	16.5	1258.0
10.15	46.5	18.5	307.0	14.15	38.5	15.5	1312.0
10.30	53.5	27.5	388.0	14.30	37.5	15.5	1365.0
10.45	46.5	21.5	456.0	14.45	37.5	15.5	1418.0
11.00	43.5	17.5	517.0	15.00	45.5	17.5	1481.0
11.15	45.5	19.5	582.0	15.15	32.5	14.5	1528.0
11.30	43.5	18.5	644.0	15.30	44.5	18.0	1590.5
11.45	28.5	11.5	684.0	15.45	35.5	15.5	1641.5
12.00	64.5	31.5	780.0	16.00	64.5	49.5	1755.5
12.15	43.5	18.5	842.0	16.15	35.5	14.5	1805.5
12.30	43.5	18.5	904.0	16.30	39.5	18.5	1863.5
12.45	43.5	17.5	965.0	16.45	27.5	11.5	1902.5
13.00	39.5	16.5	1021.0	17.00	31.5	11.5	1945.5

TABLE NO. 4

DUST COLLECTED

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9

DATE: 27-11-1963

LOAD: M.C.R.

LEFT HAND SIDE

TIME hr.min.	WEIGHT, lbs.		TIME hr.min.	WEIGHT, lbs.			
	INCREMENT	CUMULATIVE		INCREMENT	CUMULATIVE		
9.15	22.5	35.5	58.0	13.15	28.5	34.5	1093.0
9.30	25.5	40.0	123.5	13.30	26.5	36.5	1156.0
9.45	26.0	40.0	189.5	13.45	21.5	33.5	1211.0
10.00	24.5	38.5	252.5	14.00	23.5	32.5	1267.0
10.15	26.0	40.5	319.0	14.15	22.5	32.5	1322.0
10.30	30.0	42.0	391.0	14.30	23.5	32.5	1378.0
10.45	26.5	38.5	456.0	14.45	23.5	33.5	1435.0
11.00	27.5	39.5	523.0	15.00	25.5	39.5	1500.0
11.15	25.5	37.5	586.0	15.15	23.5	35.5	1559.0
11.30	25.5	37.5	649.0	15.30	24.5	35.5	1619.0
11.45	17.5	26.5	693.0	15.45	37.5	35.5	1692.0
12.00	36.5	52.5	782.0	16.00	62.5	61.5	1816.0
12.15	26.5	36.5	845.0	16.15	51.5	29.5	1897.0
12.30	25.5	35.5	906.0	16.30	25.5	44.5	1967.0
12.45	25.5	39.5	971.0	16.45	18.5	21.5	2007.0
13.00	24.5	34.5	1030.0	17.00	21.5	28.5	2057.0

TABLE NO. 5

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9

DATE: 26-11-1963

APPARATUS NO. 2

LOAD: E.C.R.

CYCLONE BEAKER NO. 2

FILTER NO. 2

LEFT HAND SIDE

SAMP- LING POINT	TIME	VELOC. HEAD	ORIFICE P. DROP	STATIC PR.	FLUE GAS TEMP.	AMB. TEMP.	BARO.
	hr.min.	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mV	°C	in. Hg.
A.1	11.30	4.8	17.5	6.0	5.4	37	28 <sup>13</sup> / <sub>16</sub>
	11.35	4.8	17.5	7.0	5.5	37	
	11.40	4.8	17.5	7.0	5.5	37	
A.2	11.41	6.2	22.5	9.0	5.5	37	
	11.46	6.3	22.8	8.0	5.5	37	
	11.51	6.2	22.4	8.0	5.5	37	
A.3	11.52	6.2	22.4	8.0	5.5	37	
	11.57	6.2	22.5	8.0	5.5	37	
	12.02	6.2	22.4	8.0	5.5	37	
A.4	12.03	6.0	22.0	9.0	5.5	37	
	12.08	6.0	22.0	9.0	5.5	37.5	
	12.13	6.0	22.0	8.0	5.5	37.5	
A.5	12.14	6.0	22.0	8.0	5.5	37.5	
	12.19	6.2	22.0	9.0	5.5	37.5	
	12.24	6.2	22.0	8.0	5.5	37.2	
A.6	12.25	4.0	15.0	7.0	5.5	37.2	
	12.30	4.0	15.0	8.0	5.6	37.5	
	12.35	4.2	15.0	7.0	5.6	37.6	

TABLE NO. 5

(Continued)

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9

DATE: 26-11-1963

APPARATUS NO. 2

LOAD: E.C.R.

CYCLONE BEAKER NO. 2

FILTER NO. 2

LEFT HAND SIDE

SAMP- LING POINT	TIME	VELOC. HEAD	ORIFICE P. DROP	STATIC PR.	FLUE GAS TEMP.	AMB. TEMP.	BARO.
	hr.min.	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mV	°C	in. Hg.
B.1	12.47	5.5	20.0	8.0	5.3	37.1	28 <sup>13</sup> / <sub>16</sub>
	12.52	5.4	20.0	7.0	5.3	37.2	
	12.57	5.6	20.0	8.0	5.3	37.2	
B.2	12.58	6.4	23.5	7.0	5.5	37.4	
	13.03	6.5	23.5	9.0	5.5	37.2	
	13.08	6.4	23.8	8.0	5.5	37.2	
B.3	13.09	6.4	23.2	8.0	5.55	37.2	
	13.14	6.4	23.3	8.0	5.5	37.0	
	13.19	6.3	23.0	9.0	5.5	37.0	
B.4	13.20	6.5	23.4	8.0	5.6	37.0	
	13.25	6.6	24.0	8.0	5.6	36.6	
	13.30	6.6	24.0	8.0	5.6	36.4	
B.5	13.31	6.6	23.9	7.0	5.6	36.4	
	13.36	6.6	24.0	8.5	5.6	36.3	
	13.41	6.6	23.5	8.0	5.5	36.3	
B.6	13.42	4.4	16.0	7.0	5.5	36.4	
	13.47	4.4	16.0	8.0	5.5	37.2	
	13.52	4.4	16.2	7.5	5.5	38.0	

TABLE NO. 6

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9							
<u>DATE:</u> 26-11-1963				<u>APPARATUS NO.</u> 2			
<u>LOAD:</u> E.C.R.				<u>CYCLONE BEAKER NO.</u> 2			
				<u>FILTER NO.</u> 2			
<u>RIGHT HAND SIDE</u>							
SAMP- LING POINT	TIME	VELOC. HEAD	ORIFICE P. DROP	STATIC PR.	FLUE GAS TEMP.	AMB. TEMP.	BARO.
	hr.min.	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mV	°C	in. Hg.
C.1	14.28	5.2	19.0	12.0	5.5	40.0	28 <sup>13</sup> / <sub>16</sub>
	14.33	5.5	20.0	14.0	5.5	40.9	
	14.38	5.6	20.0	13.0	5.5	40.8	
C.2	14.39	5.8	22.0	13.0	5.5	41.0	
	14.44	6.0	22.0	13.0	5.53	41.0	
	14.49	6.0	22.0	14.0	5.5	41.0	
C.3	14.50	5.8	22.0	13.6	5.5	41.5	
	14.55	6.0	22.0	14.0	5.5	42.0	
	15.00	5.8	22.0	14.0	5.5	42.3	
C.4	15.01	5.5	20.0	13.0	5.5	42.3	
	15.06	5.4	20.0	12.0	5.5	42.5	
	15.11	5.5	20.0	13.0	5.5	42.8	
C.5	15.12	5.5	20.0	12.0	5.5	43.0	
	15.17	5.5	20.0	13.0	5.45	43.5	
	15.22	5.6	20.0	13.0	5.48	43.6	
C.6	15.23	5.4	20.0	12.0	5.45	43.6	
	15.28	5.4	19.5	12.0	5.4	43.7	
	15.33	5.4	19.0	12.0	5.4	43.8	



TABLE NO. 6

(Continued)

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9							
DATE: <u>26-11-1963</u>				APPARATUS NO. <u>2</u>			
LOAD: <u>E.C.R.</u>				CYCLONE BEAKER NO. <u>2</u>			
				FILTER NO. <u>2</u>			
RIGHT HAND SIDE							
SAMP- LING POINT	TIME	VELOC. HEAD	ORIFICE P. DROP	STATIC PR.	FLUE GAS TEMP.	AMB. TEMP.	BARO.
	hr.min.	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mV	°C	in. Hg.
D.1	15.45	5.5	21.0	12.0	5.4	44	28 <sup>13</sup> / <sub>16</sub>
	15.50	5.8	21.0	13.0	5.4	44	
	15.55	5.8	21.0	13.0	5.4	44	
D.2	15.56	5.8	21.0	13.0	5.4	44	
	16.01	5.8	20.5	13.0	5.4	44	
	16.06	5.8	21.0	13.0	5.45	44	
D.3	16.07	6.0	22.5	13.0	5.45	44	
	16.12	5.8	21.0	13.0	5.45	44	
	16.17	5.8	20.5	13.0	5.40	44	
D.4	16.18	5.8	21.0	14.0	5.45	44	
	16.23	5.8	20.5	13.0	5.5	44	
	16.28	5.8	21.0	15.0	5.5	43.5	
D.5	16.29	5.8	21.5	14.0	5.5	43.8	
	16.34	5.5	20.0	13.0	5.5	43.5	
	16.39	5.5	19.8	14.0	5.52	44.0	
D.6	16.40	5.2	18.5	13.0	4.50	44.0	
	16.45	5.0	18.0	15.0	4.50	43.8	
	16.50	5.2	19.0	14.0	4.50	43.8	

TABLE NO. 7

DUST COLLECTOR TEST AT UMGENI POWER STATION, BOILER NO. 9							
<u>DATE: 27-11-1963</u>				<u>APPARATUS NO. 1</u>			
<u>LOAD: M.C.R.</u>				<u>CYCLONE BEAKER NO. 3</u>			
				<u>FILTER NO. 3</u>			
<u>RIGHT HAND SIDE</u>							
SAMP- LING POINT	TIME	VELOC. HEAD	ORIFICE P. DROP	STATIC PR.	FLUE GAS TEMP.	AMB. TEMP.	BARO.
	hr.min.	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mV	°C	in. Hg.
D.1	10.34	7.2	25.5	6	5.7	38.5	28 <sup>13</sup> / <sub>16</sub>
	10.39	7.5	26.8	5	5.7	38.3	
	10.44	7.5	26.8	5	5.7	38.3	
D.2	10.45	7.2	25.5	6	5.8	38.3	
	10.50	7.5	26.5	7	5.8	38.3	
	10.55	7.5	26.5	7	5.85	38.3	
D.3	10.56	7.6	27.0	5	5.85	38.3	
	11.01	7.6	27.0	6	5.9	38.3	
	11.06	7.6	27.0	5	5.85	38.3	
D.4	11.07	7.6	27.0	6	5.85	38.3	
	11.12	7.6	27.0	6	5.85	38.3	
	11.17	7.6	27.0	6	5.85	38.5	
D.5	11.18	7.4	26.0	5	5.8	38.9	
	11.23	7.5	26.5	6	5.8	39.0	
	11.28	7.5	26.5	5	5.8	39.1	
D.6	11.29	7.4	26.0	4	5.8	39.2	
	11.34	7.4	26.0	5	5.75	39.3	
	11.39	7.5	26.5	6	5.75	39.5	

TABLE NO. 7

(Continued)

## DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9

DATE: 27-11-1963APPARATUS NO. 1LOAD: M.C.R.CYCLONE BEAKER NO. 3FILTER NO. 3RIGHT HAND SIDE

SAMP- LING POINT	TIME	VELOC. HEAD	ORIFICE P. DROP	STATIC PR.	FLUE GAS TEMP.	AMB. TEMP.	BARO.
	hr.min.	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mV	°C	in. Hg.
C.1	11.48	6.4	23.0	1	5.85	38.8	28 <sup>13</sup> / <sub>16</sub>
	11.53	6.6	24.0	1	5.85	38.3	
	11.58	6.8	24.5	1	5.80	38.1	
C.2	11.59	7.0	25.0	2	5.85	38.0	
	12.04	7.2	25.8	4	5.85	38.0	
	12.09	7.2	25.7	5	5.88	38.0	
C.3	12.10	7.2	25.8	5	5.88	38.0	
	12.15	7.4	26.0	6	5.90	38.0	
	12.20	7.4	26.0	6	5.90	38.0	
C.4	12.21	7.0	25.0	5	5.90	38.0	
	12.26	7.2	25.5	5	5.9	38.0	
	12.31	7.2	25.5	5	5.9	38.0	
C.5	12.32	6.8	24.0	5	5.9	38.0	
	12.37	6.8	24.5	5	5.9	38.0	
	12.42	7.0	25.0	6	5.85	38.0	
C.6	12.43	6.8	24.2	7	5.8	38.5	
	12.48	6.6	24.0	8	5.8	38.5	
	12.53	6.6	24.0	7	5.8	38.7	

TABLE NO. 8

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9

DATE: 27-11-1963

APPARATUS NO. 1

LOAD: M.C.R.

CYCLONE BEAKER NO. 4

FILTER NO. 5

LEFT HAND SIDE

SAMP- LING POINT	TIME	VELOC. HEAD	ORIFICE P. DROP	STATIC PR.	FLUE GAS TEMP.	AMB. TEMP.	BARO.
	hr.min.	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mV	°C	in. Hg.
B.1	13.22	8.20	29.0	3	5.4	41	28 <sup>13</sup> / <sub>16</sub>
	13.27	8.20	29.0	0	5.45	41	
	13.32	8.40	30.0	2	5.60	40.5	
B.2	13.33	8.50	30.0	1	5.65	39.8	
	13.38	8.50	30.0	2	5.63	37.5	
	13.43	8.60	30.5	3	5.61	36.8	
B.3	13.44	8.50	30.0	2	5.60	36.8	
	13.49	8.60	31.0	1	5.60	38.6	
	13.54	8.50	30.5	2	5.55	39.2	
B.4	13.55	8.65	31.5	1	5.60	39.5	
	14.00	8.80	32.0	1	5.55	39.8	
	14.05	8.80	31.8	2	5.52	40.0	
B.5	14.06	8.70	31.0	0	5.50	40.0	
	14.11	8.70	31.5	1	5.50	40.2	
	14.16	8.80	32.0	0	5.50	40.3	
B.6	14.17	6.00	22.0	0	5.50	40.5	
	14.22	5.80	21.0	1	5.50	40.2	
	14.27	6.00	22.0	2	5.55	39.6	

TABLE NO. 8

(Continued)

## DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9

DATE: 27-11-1963

APPARATUS NO. 1

LOAD: M.C.R.

CYCLONE BEAKER NO. 4

FILTER NO. 5

LEFT HAND SIDE

SAMP- LING POINT	TIME	VELOC. HEAD	ORIFICE P. DROP	STATIC PR.	FLUE GAS TEMP.	AMB. TEMP.	BARO.
	hr.min.	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mm.H <sub>2</sub> O	mV	°C	in. Hg.
A.1	14.39	6.0	22.0	3	5.40	41	28 <sup>13</sup> / <sub>16</sub>
	14.44	6.2	22.5	1	5.40	41	
	14.49	6.3	22.8	2	5.40	41.2	
A.2	14.50	8.0	28.0	3	5.45	41.2	
	14.55	8.2	28.5	1	5.42	42.0	
	15.00	8.3	29.0	1	5.45	42.0	
A.3	15.01	8.4	30.0	2	5.35	42.0	
	15.06	8.5	30.0	1	5.35	42.1	
	15.11	8.4	29.0	2	5.30	42.3	
A.4	15.12	8.2	28.5	2	5.30	42.4	
	15.17	8.0	28.0	4	5.30	42.8	
	15.22	8.0	28.0	3	5.30	42.8	
A.5	15.23	7.6	27.0	1	5.30	43.0	
	15.28	7.5	26.5	2	5.30	42.5	
	15.33	7.5	26.5	2	5.28	43.0	
A.6	15.34	5.5	20.0	0	5.20	43.0	
	15.39	5.2	18.5	1	5.20	43.0	
	15.44	5.0	18.0	1	5.20	43.0	



TABLE NO. 9

<u>DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9</u>	
<u>E.C.R.</u>	
<u>CYCLONE BEAKER NO. 2</u>	<u>OVEN FOR 4 HOURS</u>
26.6122	73.0654
<u>25.3633</u>	<u>71.8424</u>
<u>1.2489</u>	<u>1.2230</u>
<u>FILTER NO. 2</u>	
39.9786	39.9081
<u>39.5425</u>	<u>39.5425</u>
<u>.4361</u>	<u>.3656</u>
<u>EXTRAS</u>	
25.3694	25.3702
<u>25.3633</u>	<u>25.3643</u>
<u>.0061</u>	<u>.0059</u>
TOTAL WEIGHT OF DUST COLLECTED : 1.5945 gram	

TABLE NO. 10

DUST COLLECTOR TEST AT UMGANI POWER STATION, BOILER NO. 9

M.C.R.

CYCLONE BEAKER NO. 3  
+ FILTER NO. 3

41.6822

40.8435

.8387

OVEN FOR 4 HOURS

41.6484

40.8435

.8049

CYCLONE BEAKER NO. 4  
+ FILTER NO. 5

50.7765

49.1659

1.6106

50.7408

49.1659

1.5749

TOTAL WEIGHT OF DUST COLLECTED : 2.3798 gram

TABLE NO. 11

VELOCITIES IN DUCT AND PROBE

LOAD: E.C.R.

DATE: 26-11-1963

LEFT HAND SIDE

SAMP- LING POINT	AVERAGE TEMPER- ATURE	MEAN VELOCITY HEAD	MEAN VELOCITY IN SAMP- LING POINT V <sub>1</sub>	MEAN ORIFICE PRESSURE DROP	MEAN VELOCITY IN PROBE V <sub>2</sub>
NO.	°A	mm.H <sub>2</sub> O	m/sec.	mm.H <sub>2</sub> O	m/sec.
A.1	402	4.80	10.42	17.50	10.42
A.2	402	6.23	11.86	22.57	11.90
A.3	402	6.20	11.84	22.43	11.83
A.4	402	6.00	11.65	22.00	11.74
A.5	402	6.13	11.76	22.00	11.74
A.6	404	4.07	9.57	15.00	9.60
B.1	399	5.50	11.11	20.00	11.11
B.2	402	6.43	12.06	23.60	12.12
B.3	403	6.37	12.02	23.13	12.04
B.4	405	6.57	12.23	23.80	12.27
B.5	404	6.60	12.24	23.80	12.27
B.6	402	4.40	9.97	16.07	9.97

TABLE NO. 12

VELOCITIES IN DUCT AND PROBE

LOAD: E.C.R.

DATE: 26-11-1963

RIGHT HAND SIDE

SAMP- LING POINT	AVERAGE TEMPER- ATURE	MEAN VELOCITY HEAD	MEAN VELOCITY IN SAMP- LING POINT $V_1$	MEAN ORIFICE PRESSURE DROP	MEAN VELOCITY IN PROBE $V_2$
NO.	°A	mm.H <sub>2</sub> O	m/sec.	mm.H <sub>2</sub> O	m/sec.
C.1	402	5.43	11.08	19.67	11.07
C.2	403	5.93	11.59	22.00	11.76
C.3	402	5.87	11.52	22.00	11.74
C.4	402	5.47	11.12	20.00	11.15
C.5	402	5.53	11.18	20.00	11.15
C.6	401	5.40	11.04	19.50	10.99
D.1	400	5.80	11.42	21.00	11.42
D.2	401	5.80	11.44	20.83	11.39
D.3	401	6.77	12.36	21.33	11.49
D.4	402	5.80	11.45	20.83	11.40
D.5	403	5.60	11.27	20.43	11.27
D.6	384	5.13	10.53	18.50	10.44

TABLE NO. 13

VELOCITIES IN DUCT AND PROBE

LOAD: M.C.R.

DATE: 27-11-1963

LEFT HAND SIDE

SAMP- LING POINT	AVERAGE TEMPER- ATURE	MEAN VELOCITY HEAD	MEAN VELOCITY IN SAMP- LING POINT $V_1$	MEAN ORIFICE PRESSURE DROP	MEAN VELOCITY IN PROBE $V_2$
NO.	$^{\circ}$ A	mm.H <sub>2</sub> O	m/sec.	mm.H <sub>2</sub> O	m/sec
A.1	397	6.17	11.74	22.43	11.67
A.2	398	8.17	13.52	28.50	13.26
A.3	396	8.43	13.70	29.67	13.51
A.4	395	8.07	13.39	28.17	13.12
A.5	395	7.57	12.97	26.67	12.82
A.6	394	5.23	10.77	18.83	10.58
B.1	399	8.27	13.62	29.33	13.48
B.2	406	8.53	13.96	30.17	13.81
B.3	400	8.53	13.85	30.50	13.83
B.4	400	8.75	14.03	31.77	14.03
B.5	399	8.73	13.99	31.50	13.99
B.6	399	5.93	11.54	21.67	11.47



TABLE NO. 14

VELOCITIES IN DUCT AND PROBE

LOAD: M.C.R.

DATE: 27-11-1963

RIGHT HAND SIDE

SAMP- LING POINT	AVERAGE TEMPER- ATURE	MEAN VELOCITY HEAD	MEAN VELOCITY IN SAMP- LING POINT V <sub>1</sub>	MEAN ORIFICE PRESSURE DROP	MEAN VELOCITY IN PROBE V <sub>2</sub>
NO.	°A	mm.H <sub>2</sub> O	m/sec.	mm.H <sub>2</sub> O	m/sec.
C.1	404	6.60	12.25	23.83	12.16
C.2	405	7.13	12.74	25.50	12.63
C.3	406	7.33	12.94	25.90	12.74
C.4	406	7.13	12.76	25.33	12.60
C.5	406	6.86	12.52	24.50	12.37
C.6	404	6.67	12.31	24.07	12.20
D.1	403	7.40	12.95	26.36	12.82
D.2	404	7.40	12.97	26.16	12.75
D.3	405	7.60	13.11	27.00	13.03
D.4	405	7.60	13.11	27.00	13.03
D.5	404	7.46	13.02	26.33	12.84
D.6	404	7.43	12.99	26.16	12.82

TABLE NO. 15

DUCT AREA

POSITIONS	DIMENSIONS	AREA (EACH) in <sup>2</sup>
A.1, A.2, A.3, A.4, A.5, A.6	95.5" x 39"	310.375
B.1, B.2, B.3, B.4, B.5, B.6		
C.1, C.2, C.3, C.4, C.5, C.6		
D.1, D.2, D.3, D.4, D.5, D.6		

TABLE NO. 16

FLUE GAS VOLUME

SAMPLING POINT		AREA (EACH)	RIGHT HAND SIDE		LEFT HAND SIDE	
Number		in <sup>2</sup>	$\Sigma$ Vi m/sec.	Vol. Q. 10,000 ft <sup>3</sup> in 4 hours	$\Sigma$ Vi m/sec.	Vol. Q. 10,000 ft <sup>3</sup> in 4 hours
A. 1, A. 2, A. 3, A. 4, A. 5, A. 6					136.73 m/sec.	1392.058
B. 1, B. 2, B. 3, B. 4, B. 5, B. 6					448.588 ft/sec.	
C. 1, C. 2, C. 3, C. 4, C. 5, C. 6	310.375		136 m/sec.			
D. 1, D. 2, D. 3, D. 4, D. 5, D. 6			446.193 ft/sec.	1324.626		

TABLE NO. 17

FLUE GAS VOLUME

SAMPLING POINT		AREA (EACH)	RIGHT HAND SIDE		LEFT HAND SIDE	
Number		in <sup>2</sup>	$\Sigma$ Vi m/sec.	Vol. Q. 10,000 ft <sup>3</sup> in 4 hours	Vi m/sec.	Vol. Q. 10,000 ft <sup>3</sup> in 4 hours
A. 1, A. 2, A. 3, A. 4, A. 5, A. 6						1599.244
B. 1, B. 2, B. 3, B. 4, B. 5, B. 6					157.08 m/sec.	
C. 1, C. 2, C. 3, C. 4, C. 5, C. 6	310.375		153.67 m/sec.		515.353 ft/sec.	
D. 1, D. 2, D. 3, D. 4, D. 5, D. 6			504.166 ft/sec.	1564.528		

TABLE NO. 18

## VOLUME ASPIRATED

SIDE	PROBE AREA (AP)	$\Sigma V_2$ m/sec.	VOLUME SAMPLED ( $Q_2$ ) Ft <sup>3</sup>	RATIO VOLUME EMITTED TO VOLUME SAMPLED		CORRECTION FACTOR K.
				Actual (R)	Theoretical (R)	
M.C.P.						
	R.H.	.768	204.502	33853	33678	1.005
L.H.	.768	135.27 m/sec. 443.798 ft/sec. 137.01 m/sec. 449.507 ft/sec.	207.133	33603	33678	0.998

TABLE NO. 19

## VOLUME ASPIRATED

SIDE	PROBE AREA (AP)	$\Sigma V_2$ m/sec.	VOLUME SAMPLED ( $Q_2$ ) Ft <sup>3</sup>	RATIO VOLUME EMITTED TO VOLUME SAMPLED		CORRECTION FACTOR K.
				Actual (R)	Theoretical (R)	
M.C.P.						
	R.H.	0.771	230.677	33911	33549	1.01
L.H.	0.771	151.99 m/sec. 498.654 ft/sec. 155.57 m/sec. 510.399 ft/sec.	236.110	33866	33549	1.009

TABLE NO. 20.

DUST EMISSION.

	UNIT	R.H.	L.H.	TOTAL.	
M.C.R.	Weight of Ash Sampled (W)	Gram	0.8049	1.5749	2.3798
	Weight of Ash Emitted (E)	lb.	120.345	235.168	355.513
	Weight of Ash Collected in 4 Hours.	lb.	1012.8	958.4	1971.2

	UNIT	TOTAL
E.C.R.	Weight of Ash Sampled (W)	Gram 1.5945
	Weight of Ash Emitted (E)	lb 237.124
	Weight of Ash Collected in 4 Hours.	lb 1074.98

TABLE NO. 21.

E.C.R.

GRAIN SIZE.	EMITTED ASH ANALYSIS.	MASS OF ASH EMITTED.	COLLECTED ASH ANALYSIS	MASS OF ASH COLLECTED	FRACTIONAL EFFICIENCY.
Microns	%	lbs	%	lbs	%
0 - 1.4	1.63	3.87	0.53	5.69	59.52
1.4 - 3.3	4.88	11.57	1.36	14.62	55.82
3.3 - 5.0	16.26	38.56	3.18	34.18	46.99
5.0 - 7.4	23.88	56.63	5.39	57.94	50.57
7.4 - 11.6	33.69	79.89	9.33	100.30	55.66
11.6 - 19.2	14.03	33.27	8.72	93.74	73.81
19.2 - 23.7	1.71	4.05	3.60	38.70	90.53
> 23.7	3.92	9.29	67.85	729.37	91.49
TOTAL	100.00	237.13	99.96	1074.55	81.92

TABLE NO. 22

M.C.R.

GRAIN SIZE.	EMMITTED ASH ANALYSIS	MASS OF ASH EMITTED	COLLECTED ASH ANALYSIS	MASS OF ASH COLLECTED	FRACTIONAL EFFICIENCY
Microns	%	lbs	%	lbs	%
1.0 - 1.4	3.35	11.91	0.54	10.64	47.18
1.4 - 3.3	6.02	21.40	1.47	28.98	57.52
3.3 - 5.0	13.75	48.88	2.96	58.35	54.42
5.0 - 7.4	35.85	127.45	4.87	96.00	42.96
7.4 - 11.6	28.43	101.07	7.99	157.50	60.91
11.6 - 19.2	5.44	19.34	7.86	154.94	88.90
19.2 - 23.7	1.14	4.05	3.13	61.70	93.84
23.7 - 26.6	0.55	1.96	1.54	30.36	93.93
>26.6	5.47	19.45	69.64	1372.74	98.60
TOTAL	100.00	355.513	100.00	1971.20	84.72



APPENDIX.

PARTICLE SIZE ANALYSIS OF FLY-ASH SAMPLES  
UMGENI POWER STATION.

Description of Samples :

The samples consisted of fly-ash from Umgeni Power Station and were designated as follows :

- (a) E.C.R., probe sample;
- (b) M.C.R., probe sample;
- (c) E.C.R., primary collector sample (R.H.);
- (d) E.C.R., secondary collector sample (R.H.);
- (e) E.C.R., primary collector sample (L.H.);
- (f) E.C.R., secondary collector sample (L.H.);
- (g) M.C.R., primary collector sample (R.H.);
- (h) M.C.R., secondary collector sample (R.H.);
- (i) M.C.R., primary collector sample (L.H.);
- (j) M.C.R., secondary collector sample (L.H.);

The average particle density for the samples was 2.185 gm/cc.

Method of Analysis :

A screen analysis was performed on samples (c) - (j). As requested, the analysis of samples (a) and (b) and the -325 mesh fractions of samples (c) - (j) was done by means of a Bahco Centrifugal Dust Classifier.

RESULTS :

Screen Analysis (Dry).

For each case three samples were analysed and all subsequent calculations were based on the mean values obtained.

(c) E.C.R., ....

(c) E.C.R., primary collector sample (R.H.).

Size fraction	Sample A	Sample B	Sample C	Average
Mesh	grams	grams	grams	grams
<60	21.15	20.76	21.39	21.10
60-100	22.81	22.60	22.43	22.61
100-150	13.18	19.95	12.92	13.02
150-200	2.91	2.70	2.80	2.80
200-325	7.75	6.92	7.16	7.26
>325	32.20	34.07	33.30	33.21

(d) E.C.R., secondary collector sample (R.H.).

Size fraction	Sample A	Sample B	Sample C	Average
Mesh	grams	grams	grams	grams
<60	3.00	2.98	3.17	3.05
60-100	9.22	9.25	9.55	9.34
100-150	14.84	16.78	18.79	16.80
150-200	6.04	5.55	4.62	5.40
200-325	22.34	21.07	21.60	21.67
>325	44.56	44.37	42.27	43.74

(e) E.C.R., primary collector sample (L.H.).

Size fraction	Sample A	Sample B	Sample C	Average
Mesh	grams	grams	grams	grams
<60	15.10	15.15	15.07	15.11
60-100	26.12	25.98	25.92	26.01
100-150	16.70	19.16	18.22	18.03
150-200	4.84	3.80	3.88	4.17
200-325	9.84	8.60	9.50	9.31
>325	27.40	27.31	27.41	27.37

(f) E.C.R., secondary collector sample (L.H.).

Size fraction	Sample A	Sample B	Sample C	Average
Mesh	grams	grams	grams	grams
<60	1.52	1.58	1.55	1.55
60-100	6.40	6.48	6.58	6.49
100-150	16.05	17.68	13.83	15.85
150-200	8.38	6.33	6.83	7.18
200-325	23.55	24.98	25.05	24.53
>325	44.10	42.95	46.16	44.40

(g) M.C.R., primary collector sample (R.H.).

Size fraction	Sample A	Sample B	Sample C	Average
Mesh	grams	grams	grams	grams
<60	34.14	34.38	34.44	34.32
60-100	18.85	18.88	18.55	18.76
100-150	11.47	10.32	10.15	10.65
150-200	2.80	3.40	3.05	3.06
200-325	6.75	7.37	7.39	7.17
>325	25.99	25.65	26.42	26.02

(h) ...../

(h) M.C.R., secondary collector sample (R.H.).

Size fraction	Sample A	Sample B	Sample C	Average
Mesh	grams	grams	grams	grams
<60	6.75	7.04	7.05	6.95
60-100	11.60	11.75	11.72	11.65
100-150	13.70	14.49	14.06	14.08
150-200	6.69	6.65	6.12	6.49
200-325	20.35	19.81	21.96	20.71
>325	40.91	40.26	39.09	39.08

(i) M.C.R., primary collector sample (L.H.).

Size fraction	Sample A	Sample B	Sample C	Average
Mesh	grams	grams	grams	grams
<60	26.24	26.02	25.89	26.05
60-100	21.80	22.00	21.75	21.85
100-150	12.29	12.44	12.68	12.47
150-200	3.82	3.39	3.42	3.54
200-325	7.60	7.70	7.60	7.63
>325	28.25	28.45	28.66	28.46

(j) M.C.R., secondary collector sample (L.H.).

Size fraction	Sample A	Sample B	Sample C	Average
Mesh	grams	grams	grams	grams
<60	4.45	4.41	4.42	4.43
60-100	9.64	9.67	9.74	9.65
100-150	16.51	15.40	18.02	16.68
150-200	6.82	5.84	5.16	5.94
200-325	23.25	22.85	21.14	22.41
>325	39.33	41.83	41.52	40.89

Bahco Analysis Results.

(a) E.C.R., probe sample: Sample weight:  $G_u = 1.1892$  grams  
Residue on screen:  $G_f = 0.0004$  grams

Spacing Piece No.	Grain size limit, microns		Residue, grams		Cumulative weight % above grain size limit
	Ideal particle diameter $d'$	Actual particle diameter $d = d' / 1.5\sqrt{\rho}$	$G_a$	$G_a + G_f$	
18.5	3.2	1.4	1.1694	1.1698	98.37
17	7.4	3.3	1.1114	1.1118	93.49
16	11.0	5.0	0.9180	0.9184	77.23
14	16.5	7.4	0.6341	0.6345	53.35
12	25.7	11.6	0.2334	0.2338	19.66
8	42.5	19.2	0.0665	0.0669	5.63
4	52.5	23.7	0.0462	0.0466	3.92
0	59.0	26.6	-	-	-

(b) M.C.R., probe sample: Sample weight:  $G_u = 1.9348$  grams  
 Residue on screen:  $G_f = 0.0065$  grams

Spacing Piece No.	Grain size limit, microns		Residue, grams		Cumulative weight % above grain size limit
	Ideal particle diameter $d'$	Actual particle diameter $d = d' / 1.5\sqrt{\rho}$	$G_a$	$G_a = G_f$	
18.5	3.2	1.4	1.8635	1.8700	96.65
17	7.4	3.3	1.7470	1.7535	90.63
16	11.0	5.0	1.4810	1.4875	76.88
14	16.5	7.4	0.7873	0.7938	41.03
12	25.7	11.6	0.2373	0.2438	12.60
8	42.5	19.2	0.1320	0.1385	7.16
4	52.5	23.7	0.1100	0.1165	6.02
0	59.0	26.6	0.0993	0.1058	5.47

(c) E.C.R., primary collector sample (R.H.) (-325 mesh):  
 Sample weight:  $G_u = 14.1816$  grams  
 Residue on screen:  $G_f = 0$  grams

Spacing Piece No.	Grain size limit, microns		Residue, grams		Cumulative weight % above grain size limit
	Ideal particle diameter $d'$	Actual particle diameter $d = d' / 1.5\sqrt{\rho}$	$G_a$	$G_a + G_f$	
18.5	3.2	1.4	13.9689	13.9689	98.50
17	7.4	3.3	13.1882	13.1882	93.00
16	11.0	5.0	11.4049	11.4049	80.42
14	16.5	7.4	8.6034	8.6034	60.67
12	25.7	11.6	4.5669	4.5669	32.20
8	42.5	19.2	1.9974	1.9974	14.08
4	52.5	23.7	1.2096	1.2096	8.53
0	59.0	26.6	0.9039	0.9039	6.37

(d) E.C.R., secondary collector sample (R.H.) (-325 mesh):  
 Sample weight:  $G_u = 13.6262$  grams  
 Residue on screen:  $G_f = 0$  grams

Spacing Piece No.	Grain size limit, microns		Residue, grams		Cumulative weight % above grain size limit
	Ideal particle diameter $d'$	Actual particle diameter $d = d' / 1.5\sqrt{\rho}$	$G_a$	$G_a + G_f$	
18.5	3.2	1.4	13.4449	13.4449	98.67
17	7.4	3.3	13.0110	13.0110	95.49
16	11.0	5.0	12.0162	12.0162	88.18
14	16.5	7.4	10.3448	10.3448	75.92
12	25.7	11.6	7.2395	7.2395	53.13
8	42.5	19.2	4.0966	4.0966	30.06
4	52.5	23.7	2.7161	2.7161	19.93
0	59.0	26.6	2.1053	2.1053	15.45

(e) B.C.R., primary collector sample (L.H.) (-325 mesh);  
 Sample weight : Gu = 14.2742 gms.  
 Residue on screen: Gf = 0 gms.

Spacing Piece No.	Grain size limit, microns		Residue, grams		Cumulative weight % above grain size limit.
	Ideal particle diameter d'	Actual particle diameter $d = d' / 1.5 \sqrt{p}$	Ga	Ga + Gf	
18.5	3.2	1.4	13.9890	13.9890	98.00
17	1.4	3.3	13.3564	13.3564	93.57
16	11.0	5.0	11.9190	11.9190	83.50
14	16.5	7.4	9.4356	9.4356	66.10
12	25.7	11.6	5.6520	5.6520	39.60
8	42.5	19.2	2.8109	2.8109	19.69
4	52.5	23.7	1.8765	1.8765	13.15
0	59.0	26.6	1.4714	1.4714	10.31

(f) B.C.R., secondary collector sample (L.H.) (-325 mesh)  
 Sample weight : Gu = 14.0319 gms.  
 Residue on screen : Gf = 0 gms.

Spacing Piece No..	Grain size limit, microns.		Residue, grams		Cumulative weight % above grain size limit.
	Ideal particle diameter d'	Actual particle diameter $d = d' / 1.5 \sqrt{p}$	Ga	Ga + Gf	
18.5	3.2	1.4	13.8800	13.8800	98.92
17.0	7.4	3.3	13.4940	13.4940	96.17
16.0	11.0	5.0	12.5334	12.5334	89.32
14	16.5	7.4	10.8426	10.8426	77.27
12	25.7	11.6	7.6934	7.6934	54.83
8	42.5	19.2	4.3794	4.3794	31.21
4	52.5	23.7	2.9222	2.9222	20.83
0	59.0	26.6	2.2920	2.2920	16.33



(g) M.C.R., primary collector sample (R.H.) (-325 mesh);  
 Sample weight : Gu = 14.5755 gms.  
 Residue on screen : Gf = 0 gms.

Spacing Piece No.	Grain size limit, microns.		Residue, grams		Cumulative weight % above grain size limit.
	Ideal particle diameter d'	Actual particle diameter $d = d' / 1.5 \sqrt{\rho}$	Ga	Ga + Gf	
18.5	3.2	1.4	14.4061	14.4061	98.16
17.0	7.4	3.3	13.6482	13.6482	93.00
16	11.0	5.0	11.8975	11.8975	81.07
14	16.5	7.4	8.9571	8.9571	61.03
12	25.7	11.6	4.9726	4.9726	33.88
8	42.5	19.2	2.4422	2.4422	16.64
4	52.5	23.7	1.5914	1.5914	10.84
0	59.0	26.6	1.1986	1.1986	8.17

(h) M.C.R., secondary collector sample (R.H.) (-325 mesh);  
 Sample weight : Gu = 15.1220 gms.  
 Residue on screen : Gf = 0 gms.

Spacing Piece No.	Grain size limit, microns.		Residue, grams		Cumulative weight % above grain size limit.
	Ideal particle diameter d'	Actual particle diameter $d = d' / 1.5 \sqrt{\rho}$	Ga	Ga + Gf	
18.5	3.2	1.4	14.8854	14.8854	98.44
17	7.4	3.3	14.2649	14.2649	94.33
16	11.0	5.0	13.1060	13.1060	86.67
14	16.5	7.4	11.2846	11.2846	74.62
12	25.7	11.6	8.1966	8.1966	54.20
8	42.5	19.2	4.7387	4.7387	31.34
4	52.5	23.7	3.2872	3.2872	21.72
0	59.0	26.6	2.5441	2.5441	16.82



(i) M.C.R., primary collector sample (L.H.) (-325 mesh);  
 Sample weight : Gu = 14.3961 gm.  
 Residue on screen : Gf = 0 gm.

Spacing Piece No.	Grain size limit, microns.		Residue, grams		Cumulative weight % above grain size limit.
	Ideal particle diameter d'	Actual particle diameter $d=d'/1.5\sqrt{\rho}$	Ga	Ga + Gf	
18.5	3.2	1.4	14.1673	14.1673	98.41
17	7.4	3.3	13.4883	13.4883	93.69
16	11.0	5.0	11.9565	11.9565	83.05
14	16.5	7.4	9.3138	9.3138	64.76
12	25.7	11.6	5.3756	5.3756	37.34
8	42.5	19.2	2.5863	2.5863	17.97
4	52.5	23.7	1.6601	1.6601	11.53
0	59.0	26.6	1.2428	1.2428	8.63

(j) M.C.R., secondary collector sample (L.H.) (-325 mesh)  
 sample weight : Gu = 14.5421 gm.  
 Residue on screen : Gf = 0 gm.

Spacing Piece No.	Grain size limit microns.		Residue, grams		Cumulative weight % above grain size limit.
	Ideal particle diameter d'	Actual particle diameter $d=d'/1.5\sqrt{\rho}$	Ga	Ga + Gf	
18.5	3.2	1.4	14.3629	14.3629	98.76
17	7.4	3.3	13.8515	13.8515	95.25
16	11.0	5.0	12.8871	12.8871	88.62
14	16.5	7.4	11.2882	11.2882	77.62
12	25.7	11.6	8.2990	8.2990	57.07
8	42.5	19.2	4.8112	4.8112	33.08
4	52.5	23.7	3.3532	3.3532	23.06
0	59.0	26.6	2.6417	2.6417	18.17.

COMPLETE ANALYSIS.

B.C.R.

Particle size range microns	PERCENTAGE			
	Right hand collector.		Left hand collector	
	Primary	Secondary	Primary	Secondary
> 251	21.10	3.05	15.11	1.55
251 - 150	22.61	9.34	26.01	6.49
150 - 104	13.02	16.80	18.03	15.85
104 - 75	2.80	5.40	4.17	7.18
75 - 44	7.26	21.67	9.31	24.53
44 - 26.6	2.12	6.76	2.82	7.25
26.6 - 23.7	0.72	1.96	0.78	1.99
23.7 - 19.2	1.85	4.43	1.79	4.61
19.2 - 11.6	6.02	10.09	5.45	10.49
11.6 - 7.4	9.45	9.97	7.25	9.96
7.4 - 5.0	6.56	5.34	7.46	5.35
5.0 - 3.3	4.18	3.19	2.76	3.04
3.3 - 1.4	1.83	1.39	1.21	1.22
<1.4	0.50	0.58	0.55	0.48
T O T A L	100.02	100.00	100.00	99.99

COMPLETE ANALYSIS.

M.C.R.

Particle Size range microns	PERCENTAGE.			
	Right hand collector		Left hand collector	
	Primary	Secondary	Primary	Secondary
> 251	34.32	6.95	26.05	4.43
251 - 150	18.76	11.69	21.85	9.65
150 - 104	10.65	14.08	12.47	16.68
104 - 75	3.06	6.49	3.54	5.94
75 - 44	7.17	20.71	7.63	22.41
44 - 26.6	2.13	6.74	2.46	7.43
26.6 - 23.7	0.70	1.97	0.83	2.00
23.7 - 19.2	1.51	3.85	1.83	4.10
19.2 - 11.6	4.49	9.17	5.51	9.81
11.6 - 7.4	7.06	8.18	7.79	8.41
7.4 - 5.0	5.21	4.83	5.22	4.49
5.0 - 3.3	3.10	3.07	3.03	2.71
3.3 - 1.4	1.34	1.64	1.34	1.44
<1.4	0.48	0.63	0.45	0.50
T O T A L	99.98	100.00	100.00	100.00

THE ANALYSIS OF THE COMPOSITE SAMPLE WAS CALCULATED  
EMPLOYING THE FOLLOWING RELATIONS :

(a) E.C.R.

(1) Total mass of dust caught L.H. secondary = 1.494

Total mass of dust caught L.H. primary

(2) Total mass of dust caught R.H. secondary = 2.692

Total mass of dust caught R.H. primary

(3) Total mass of dust caught L.H. = 1.079

Total mass of dust caught R.H.

(b) M.C.R.

(1) Total mass of dust caught L.H. secondary = 1.349

Total mass of dust caught L.H. primary

(2) Total mass of dust caught R.H. secondary = 2.262

Total mass of dust caught R.H. primary

(3) Total mass of dust caught L.H. = 1.057

Total mass of dust caught R.H.

ANALYSIS OF COMPOSITE SAMPLES  
(CALCULATED).

Particle size range microns.	P E R C E N T A G E.	
	E.C.R.	M.C.R.
> 251	7.44	14.47
251 - 150	13.65	14.36
150 - 104	16.26	13.99
104 - 75	5.36	5.17
75 - 44	18.10	16.33
44 - 26.6	5.48	5.32
26.6 - 23.7	1.56	1.54
23.7 - 19.2	3.60	3.13
19.2 - 11.6	8.72	7.86
11.6 - 7.4	9.33	7.99
7.4 - 5.0	5.39	4.87
5.0 - 3.3	3.18	2.96
3.3 - 1.4	1.36	1.47
< 1.4	0.53	0.54
T O T A L	99.96	100.00




FIG. 4 : SET-UP FOR CALIBRATION OF NOZZLE





FIG. 2

FILTER HEAD AND NOZZLE




6.3



Beide Achsen logar. geteilt, eine von 1 bis 100, die andere bis 1000, die andere bis 1000, Einheit 100 mm.  
 Note: This figure is for the purpose of illustration only and of reduced size compared with the diagram from which the ratio  $p_C + p_V$  is determined.

COPYRIGHT CARL SCHLITZ & SCHÜLLER-HEINRICH S.A. Nr. 365 1/2 P  
**FIGURE C 1 a**  
 Calibration Curves for Apparatus No. 1.





COPYRIGHT CARL FREDERICH OERTEL & SONS, INC. NEW YORK, N.Y. N. 365 1/2 P

FIGURE C 1b  
Calibration Curves of Apparatus No. 2.

Note: This figure is for the purpose of illustration only and of reduced size compared with the diagram from which the ratio  $p_0 + p_v$  is determined.

Beide Achsen  $\log_{10}$  geteilt, eine von 1 bis 100, die andere  $p_0$ 's 1000, Einheit 100 mm.